

# Certificate of Compliance

**Certificate:** 1433868 (LR 108334)

**Master Contract:** 186200

**Project:** 1433868 (Edition 1)


**Date Issued:** July 30, 2003

**Issued to:** Whitlock Instrument, (d/b/a)  
Terra Metrics, Inc.  
1300 North Texas  
Odessa, TX 79761  
USA


*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:**

  
Alexander E. Kandathil, C.E.T.  
Certification Specialist

**Authorized by:**

  
Patricia Pasemko  
Operations Manager

## PRODUCTS

CLASS 4418 02 – OUTLET BOXES AND FITTINGS Boxes - For Hazardous Locations  
Class I, Division 1, Groups C and D; Ambient Temperature -40 °C to +80' °C.

CLASS 4418 82 – OUTLET BOXES AND FITTINGS Boxes - Certified to U.S. Standards  
Class I, Division 1, Groups C and D; Ambient Temperature -40 °C to +80' °C.

Explosion Proof Housing Model DLM-926.

## APPLICABLE REQUIREMENTS

- |                            |   |   |
|----------------------------|---|---|
| CSA Std C22.2 No 0-M1991   | - | General Requirements, Canadian Electrical Code, Part II   |
| CSA Std C22.2 No 0.4-M1982 | - | Bonding and Grounding of Electrical Equipment (Protective Grounding)                                      |
| CSA Std C22.2 No 0.5-M1982 | - | Threaded Conduit Entries  |
| CSA Std C22.2 No 30-M1987  | - | Explosion-Proof Enclosures for Use in Class I Hazardous Locations.  |
| ANSI/UL Standards UL 1203  | - | Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations. |

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



## *Supplement to Certificate of Compliance*

**Certificate:** 1433868 (LR 108334)

**Master Contract:** 186200

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

| <b>Project</b> | <b>Date</b>   | <b>Description</b>   |
|----------------|---------------|--|
| 1433868        | July 30, 2003 | Original Certification of Model DLM-926 Explosion Proof Housing. |