

Certificate of Compliance

Certificate: 1433868 (LR 108334)

Master Contract: 186200

Project: 1433868 (Edition 1)


Date Issued: July 30, 2003

Issued to: Whitlock Instrument, (d/b/a)
Terra Metrics, Inc.
1300 North Texas
Odessa, TX 79761
USA


The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by:


Alexander E. Kandathil, C.E.T.
Certification Specialist

Authorized by:


Patricia Pasemko
Operations Manager

PRODUCTS

CLASS 4418 02 – OUTLET BOXES AND FITTINGS Boxes - For Hazardous Locations
Class I, Division 1, Groups C and D; Ambient Temperature -40 °C to +80' °C.

CLASS 4418 82 – OUTLET BOXES AND FITTINGS Boxes - Certified to U.S. Standards
Class I, Division 1, Groups C and D; Ambient Temperature -40 °C to +80' °C.

Explosion Proof Housing Model DLM-926.

APPLICABLE REQUIREMENTS

- | | | |
|----------------------------|---|---|
| CSA Std C22.2 No 0-M1991 | - | General Requirements, Canadian Electrical Code, Part II |
| CSA Std C22.2 No 0.4-M1982 | - | Bonding and Grounding of Electrical Equipment (Protective Grounding) |
| CSA Std C22.2 No 0.5-M1982 | - | Threaded Conduit Entries |
| CSA Std C22.2 No 30-M1987 | - | Explosion-Proof Enclosures for Use in Class I Hazardous Locations. |
| ANSI/UL Standards UL 1203 | - | Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations. |

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Supplement to Certificate of Compliance

Certificate: 1433868 (LR 108334)

Master Contract: 186200

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1433868	July 30, 2003	Original Certification of Model DLM-926 Explosion Proof Housing.