



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1037678 (LR 108334-1)

Master Contract: 186200

Project: 1204658 (Edition 6)

Date Issued: April 12, 2001

Issued to: **Whitlock Instrument, (d/b/a)
Terra Metrics, Inc.
1300 North Texas
Odessa, TX 79761**

The products listed below are eligible to bear the CSA Mark shown, with adjacent indicator "C" and "US".
OR


The products listed below are eligible to bear the CSA Mark shown, with adjacent indicator NRTL/C.



OR



Issued by: 
D. Adams, P.Eng.

Authorized By: 
John Verwey, P.Eng.
Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Ex md IIC T4: Ambient Temperature -40 °C to +85 °C.

Class I, Div. 1, Groups A, B, C and D; T4; Ambient Temperature -40 °C to +85 °C.

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to U.S. Standards

Class I, Zone 1, Groups AEx md IIC; T4; Ambient Temperature -40 °C to +85 °C.

Class I, Div. 1, Groups A, B, C and D; T4; Ambient Temperature -40 °C to +85 °C.

Model **DNFT-ab-cde-fg**, Digital No-Flow Timer, permanently-connected, battery-operated (3.0 Vdc);

Rated Output: 240 Vdc max., 2.5 VA..

Suffixes denote the following;

ab - Divider Valve Manufacturer

cde - Model

fg - Proximity switch

Model **DNFT-AC-xx**, Digital No-Flow Timer, permanently-connected, battery-operated (3.0 Vdc);

Rated Output: 10 - 120 Vac, 2.5 VA / 10 - 240 Vdc, 2.5 VA.

Suffixes denote the following;

xx - Minor Options???

Note:

- (1) Components are certified only for installation in other certified equipment or in racks or cabinets where the suitability of the final installation is to be determined by the local inspection authority.

¹The "C" and "US" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. This includes products eligible to bear the NRTL indicator. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

²The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.